

इंटरनेट

मानक



Disclosure to Promote the Right To Information

Whereas the Parliament of India has set out to provide a practical regime of right to information for citizens to secure access to information under the control of public authorities, in order to promote transparency and accountability in the working of every public authority, and whereas the attached publication of the Bureau of Indian Standards is of particular interest to the public, particularly disadvantaged communities and those engaged in the pursuit of education and knowledge, the attached public safety standard is made available to promote the timely dissemination of this information in an accurate manner to the public.

“जानने का अधिकार, जीने का अधिकार”

Mazdoor Kisan Shakti Sangathan


“The Right to Information, The Right to Live”

“पुराने को छोड़ नये के तरफ”

Jawaharlal Nehru

“Step Out From the Old to the New”

IS 3025 (Part 50) (2001, Reaffirmed 2006): Method of Sampling and Test (Physical and Chemical) for Water and Wastewater, Part 50: Jar Test (Coagulation Test) (First Revision). ICS 13.060.50



“ज्ञान से एक नये भारत का निर्माण”

Satyanarayan Gangaram Pitroda

“Invent a New India Using Knowledge”



“ज्ञान एक ऐसा खजाना है जो कभी चुराया नहीं जा सकता है”

Bhartrhari—Nitiśatakam

“Knowledge is such a treasure which cannot be stolen”

IS 3025 (Part 50) : 2001

(Reaffirmed 2006)

भारतीय मानक

जल और अपशिष्ट जल के नमूने लेने तथा परीक्षण
(भौतिक एवं रसायनिक) की पद्धतियाँ
भाग 50 जार टैस्ट (स्कन्दन टैस्ट)
(पहला पुनरीक्षण)

Indian Standard

METHODS OF SAMPLING AND TESTS
(PHYSICAL AND CHEMICAL) FOR WATER
AND WASTE WATER

PART 50 JAR TEST (COAGULATION TEST)

(*First Revision*)

Second Reprint SEPTEMBER 2007

ICS 13.060.50; 13.060.60

© BIS 2001

BUREAU OF INDIAN STANDARDS
MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG
NEW DELHI 110002

March 2001

Price Group 3

FOREWORD

This Indian Standard (Part 50) (First Revision) was adopted by the Bureau of Indian Standards, after the draft finalized by the Water Environment Protection Sectional Committee had been approved by the Chemical Division Council.

The empirical procedure is used to determine the optimum dosage of coagulants and/or coagulant aids and pH of coagulation for a given water or wastewater for removal of turbidity, colour, dissolved minerals, phosphorus, etc.

These data can not be quantitatively obtained from a theoretical understanding of the problem and analysis of water or wastewater. During operation of a treatment unit, it is essential to perform jar test as often as necessitated by changes in composition of wastewater.

The technical committee responsible for formulation of IS 3025 : 1964 'Methods of sampling and test (physical and chemical) for water used in industry' had decided to revise the standard and publish it in separate parts. This test method is one among the different parts being published under IS 3025 series of standards.

The composition of the committee responsible for preparation of this standard is given in Annex C.

In reporting the result of a test or analysis made in accordance with this standard if the final value, observed or calculated, is to be rounded off, it shall be done in accordance with IS 2 : 1960 'Rules for rounding off numerical values (*revised*)'.

Indian Standard

**METHODS OF SAMPLING AND TESTS
(PHYSICAL AND CHEMICAL) FOR WATER
AND WASTE WATER**

PART 50 JAR TEST (COAGULATION TEST)

(First Revision)

1 SCOPE

This standard prescribes the method of determining optimum dosage of coagulants (single/mixed) coagulant aids and the optimum pH of coagulation for removal of turbidity and colour caused by colloidal and non-settleable particles followed by sedimentation under quiescent condition.

2 REFERENCES

The Indian Standards listed in Annex A contain provisions which through reference in this text, constitute provision of this standard. At the time of publication, the editions indicated were valid. All standards are subject to revision and parties to agreements based on this standard are encouraged to investigate the possibility of applying the most recent editions of the standards.

3 TERMINOLOGY

For the purpose of this standard, the definitions given in IS 7022 (Part 1) and 7022 (Part 2) shall apply.

4 OPERATING VARIABLES

4.1 The following primary variables are required to be investigated.

4.1.1 *Chemical Additives*

4.1.2 *Temperature*

4.1.3 *pH*

4.1.4 *Order of Addition and Mixing Conditions*

5 INTERFERENCES

5.1 The possible interference of optimum jar test conditions are as given below.

5.1.1 *Temperature Change*

Temperature control is very important since thermal and convection currents may occur during the test which interferes with the setting of coagulated particles.

5.1.2 *Release of Gases*

Due to chemical reaction, mechanical agitator or

temperature increase, there may be some gas release due to which coagulated flocs may float.

5.1.3 *Testing Period*

Biological activity or other factors may alter the coagulation characteristics of water on prolonged standing. To control this the sampling and testing period should be kept as minimum as possible and time shall be recorded.

6 APPARATUS

6.1 **Multiple Stirrer**

6.1.1 A multiple stirrer with continuous speed variation from 20 to 150 rpm shall be used (see Fig 1).

6.1.2 The stirring paddles shall be light, non-corrosive and having same configuration. An illuminated base is advisable to see the floc formation clearly. At the same time, it is to be noted that the illumination will not contribute any heat to the system, since heat can counteract on normal settling tendencies.

NOTE — The maintenance of constant and reproducible stirring condition is of prime importance in coagulation test. The basic requirement is for maintaining two speeds of stirring, a fast speed for initial addition and mixing (flash mix 30 seconds) of coagulant and a slow speed capable of promoting efficient flocculation (20 minutes). A stirring speed of about 200 rpm is found to give adequate mixing and a speed of 20 rpm for satisfactory flocculation for a wide range of wastewaters.

6.2 **Other Equipments**

6.2.1 *Beakers or Jars* — 1 000 ml capacity.

6.2.2 *Stop Watch*

6.2.3 *pH Meter*


6.2.4 *Turbidity Meter*

7 REAGENTS

7.1 **Quality of Reagents**

Unless specified otherwise, pure chemicals and distilled water (see IS 1070) shall be employed in tests.

NOTE — 'Pure chemicals' shall mean chemicals that do not contain impurities which affect the results of analysis.



All dimensions in millimetres.

FIG. 1 BEAKER/JAR TEST APPARATUS

7.2 Chemical Solutions

7.2.1 Stock solutions of coagulants, coagulant aids and other chemicals (*see* Annex B, for information) shall be prepared at concentrations such that quantities suitable for use in jar test can be measured accurately and with ease (*see* Table 1).

Table 1 Stock Solutions for Coagulation Test

Chemicals	Concentrations of Stock Solution of Suspension	Prepare Fresh Solution After	Remarks
(1)	(2)	(3)	(4)
Aluminium sulphate [Al ₂ (SO ₄) ₃ ·16H ₂ O]	1% (0.08%) Aluminium	1 month	—
Ferric sulphate [Fe ₂ (SO ₄) ₃ ·9H ₂ O]	1% (0.2%) Iron	1 week	Renew stock solution, if it becomes opalescent
Soluble starch	0.5 %	2 days	Dilute 10 times immediately before use
Polyacrylamide derivatives	0.5 %	1 week	Solution should be at least 1 day old. Dilute 10 times immediately, before use
Sulphuric acid (H ₂ SO ₄)	0.1 N	3 months	—
Sodium hydroxide (NaOH)	0.1 N	1 month	—
Fullers earth	0.5%	3 months	Shake well, before use

7.2.2 The volume of an 5% stock solution required to be added to a dose of d mg/l to a volume V ml of sample is: $10 \times V \times d$ ml. Coagulant aids are available in powder and liquid form. When powder aids are used for making reagents, care should be taken to add the powder to the distilled water and not in reversed order. The dissolution time may vary from several minutes to several hours. For this, the manufacturer's instructions should be strictly followed.

8 SAMPLING

Sampling shall be done in accordance with IS 3025 (Part 1).

9 PROCEDURE

9.1 Collect 10 litres of sample to be tested and store it (preferably) in a 10 litre polyethylene aspirator. Before taking sample for test, put the aspirator on its aids and roll it backward and forward vigorously to make it homogeneous.

9.2 Using 1 000 ml measuring cylinder, measure 800 ml sample into 1 000 ml tall form beakers and place them in position in multiple stirrer, taking care to keep a minimum of 5 mm gap between the stirrer blade and the inner surface of the beaker.

9.3 Take a further 250 ml of sample and determine its pH, turbidity and colour.

9.4 Transfer the required volumes of coagulant into the coagulant vessels using a graduated pipette of 10 ml.

9.5 Switch the stirrer on to fast, measure the temperature in one of the beaker and add coagulant after stirring vigorously for at least one minute. Start

the stop watch on adding the coagulant. Quickly rinse the coagulant vessels with distilled water and add the rinsings to the beakers.

9.6 One minute after adding the coagulant switch the stirrer to slow and observe beakers carefully, noting the time taken for pin-point (just visible) floc to appear in each beaker.

9.7 After 15 minutes of slow stirring switch off the stirrer and carefully remove the beakers from the stirring apparatus. Allow them to stand for 15 minutes then carefully decant 150 to 200 ml of supernatant from each beaker in clean beaker or flask. A decanted sample is nearly always satisfactory but occasionally it may be found to have small amount of floc that tends to float. In such situation collect supernatant sample at a depth of 30-40 mm using glass syphon.

9.8 Mix samples prior to turbidity measurement [see IS 3025 (Part 10) : 1984]. Measure the colour [see IS 3025 (Part 4) : 1983] turbidity and pH [see IS 3025 (Part 11) : 1983] of the samples within 3 hours and tabulate results.

9.9 Repeat these steps with different concentration of chemicals, different flash mix speed and different settling time to arrive at the optimum conditions. Optional pH, if not already known, for the coagulants of interest, may be determined by conducting test at various pH.

10 REPRODUCIBILITY

To demonstrate reproducibility duplicate set of three

each jars 1 and 4, 2 and 5 and 3 and 6 are treated simultaneously and compared.

11 REPORTING

Record the data in the following manner and report the optimum values:

Sample.....pHDate.....

Location.....Colour.....Temperature.....

Sample Size.....

1 2 3 4 5 6

Chemical, mg/l

Flash mix time, minutes

Slow mix speed, rpm

Slow mix time, minutes

Temperature, °C

Time of first floc

formulation, minutes

Setting rate

Turbidity, NTU

Colour

pH

NOTES

1 Test for residual chemicals in the treated water may also be conducted apart from normal parameters.

2 The times given are illustrative only. The speed of the mix and time may be altered as per specific conditions.

ANNEX A

(Clause 2)

LIST OF REFERRED INDIAN STANDARDS

IS No.	Title	IS No.	Title
1070 : 1992	Reagent grade water—Specification (first revision)	(Part 11) : 1983	pH value (first revision)
3025	Methods of sampling and tests (physical and chemical) for water and wastewater	(Part 21) : 1983	Total hardness (first revision)
(Part 1) : 1986	Sampling (third revision)	7022	Glossary of terms relating to water, sewage and industrial effluents and wastewater, Part 1
(Part 4) : 1983	Colour (first revision)	(Part 1) : 1973	Glossary of terms relating to water, sewage and industrial effluents and waste water, Part 2
(Part 10) : 1984	Turbidity (first revision)	(Part 2) : 1979	

ANNEX B

(Clause 7.2.1)

LIST OF COAGULANTS, COAGULANTS AIDS AND OTHER CHEMICALS

B-1 PRIME COAGULANTS

- a) Aluminium sulphate [$\text{Al}_2(\text{SO}_4)_3 \cdot 16 \text{H}_2\text{O}$]
- b) Ferric sulphate [$\text{Fe}_2(\text{SO}_4)_3 \cdot 9 \text{H}_2\text{O}$]
- c) Ferric chloride ($\text{FeCl}_3 \cdot 6 \text{H}_2\text{O}$)
- d) Ferric sulphate ($\text{FeSO}_4 \cdot 7 \text{H}_2\text{O}$)
- e) Magnesium carbonate ($\text{MgCO}_3 \cdot 3 \text{H}_2\text{O}$)
- f) Sodium aluminate (NaAlO_2)

B-2 COAGULANT AIDS

- a) Activated silica
- b) Anionic poly electrolytes
- c) Cationic poly electrolytes
- d) Nonionic polymer

B-3 OXIDISING AGENTS

- a) Chlorine (Cl_2)
- b) Chlorine dioxide (ClO_2)
- c) Potassium permanganate (KMnO_4)

- d) Calcium hypochlorite ($\text{CaOCl}_2 \cdot 4 \text{H}_2\text{O}$)
- e) Sodium hypochlorite (NaOCl)

B-4 ALKALIES

- a) Calcium carbonate (CaCO_3)
- b) Dolomitic lime (50 percent CaO , 40 percent MgO)
- c) Hydrated lime [$\text{Ca}(\text{OH})_2$]
- d) Magnesium oxide (MgO)
- e) Sodium carbonate (Na_2CO_3)
- f) Sodium hydroxide (NaOH)

B-5 WETTING AGENTS

- a) Bentonite
- b) Kaolin
- c) Other clays and minerals

B-6 OTHER CHEMICAL

Activated carbon (powdered)

ANNEX C

(Foreword)

COMMITTEE COMPOSITION

Water Environment Protection Sectional Committee, CHD 12

Chairman

SHRI D. K. BISWAS

Members

DR P. K. MATHUR

DR T. N. MAHADAVEN (Alternate)

SHRI IMRANUR RAHMAN

SHRI B. RUJ (Alternate)

SHRI A. K. GUPTA

SHRI N. G. SRIVASTAVA (Alternate)

DR P. S. RAMANATHAN

DR S. R. JAKALI (Alternate)

SHRI R. A. RAMANUJAM

SHRI N. SAMIVELU (Alternate)

SHRI S. K. JAIN

SHRI ANIL JAIN

DR (MS) B. SWAMINATHAN

DR S. NAND (Alternate)

Representing

Central Pollution Control Board, Delhi

Bhabha Atomic Research Centre, Mumbai

Central Mechanical Engineering Research Institute, Durgapur

Bharat Heavy Electricals Ltd, Haridwar

Gharda Chemicals Ltd, Maharashtra

Central Leather Research Institute, Chennai

Department of Industrial Development, Ministry of Industry, Govt of India, New Delhi
Engineers India Ltd, Gurgaon

The Fertilisers Association of India, New Delhi

(Continued on page 5)

(Continued from page 4)

<i>Members</i>	<i>Representing</i>
DR S. D. MACHIJANI	Central Pollution Control Board, Delhi
DR R. C. TRIVEDI (<i>Alternate</i>)	
SHRI SATINDER KUMAR MEHRA	ABB Alstom Power India Ltd, West Bengal
SHRI SUBRATO KUMAR BASU (<i>Alternate</i>)	
SHRI BAKUL B. DAVE	Hindustan Lever Ltd, Mumbai
SHRI U. P. SINGH (<i>Alternate</i>)	
DR ANIL BHASKER	ICMA, Mumbai
SHRI B. B. NARNLA (<i>Alternate</i>)	
DR K. R. P. SINGH	Industrial Toxicology Research Centre, Lucknow
DR KRISHNA GOPAL (<i>Alternate</i>)	
SHRI M. N. VYAS	Indian Petro Chemicals Corpn Ltd, Vadodra, Gujarat
DR J. D. DESAI (<i>Alternate</i>)	
DR V. K. VERMA	Shriram Institute for Industrial Research, Delhi
SHRI M. S. DHINGRA (<i>Alternate</i>)	
DR M. P. SINGH	Indian Oil Corporation Ltd, Faridabad
DR A. S. MATHUR (<i>Alternate</i>)	
DR P. S. MINHAS	Central soil Salinity Research Institute, Karnal
SHRI P. M. KHANDERIA	Tata Chemicals Ltd, Gujarat
SHRI J. M. KHAN (<i>Alternate</i>)	
SHRI SUNIL SACHDEVA	Thermax Limited, Pune
SHRI S. S. BASARGEKAR (<i>Alternate</i>)	
SHRI A. K. JINDAL	Thermax Fuji Electric Ltd, Pune
DR S. K. GHOSH	National Institute of Occupational Health, Ahmedabad
SHRI S. B. SAHAY	National Thermal Power Corpn Ltd, West Bengal
SHRI R. L. SRIVASTAVA (<i>Alternate</i>)	
SHRI S. M. SHINGOTE	National Council for Cement and Building Materials, New Delhi
SHRI V. P. CHATTERJEE (<i>Alternate</i>)	
DR G. K. GUREJA	Thermax Limited (CI), Pune
SHRI S. K. CHOPRA (<i>Alternate</i>)	
DR S. K. KAPOOR	DRDO, New Delhi
DR (SHRIMATI) KSHIPRA MISHRA (<i>Alternate</i>)	
SHRI M. R. RAJPUT	Regional Labour Institute, Kanpur
DR S. N. BANERJEE (<i>Alternate</i>)	
SHRI D. K. DUA	Punjab Pollution Control Board, Punjab
DR (SHRIMATI) H. K. PARWANA (<i>Alternate</i>)	
REPRESENTATIVE	The Dharamsi Morarji Chemical Co Ltd, Mumbai
REPRESENTATIVE	Indian Meteorological Department, Safdarjung Airport, New Delhi
DR DIPAK CHAKRABORTY	West Bengal Pollution Control Board, Calcutta
DR UJJAL MUKHERJEE (<i>Alternate</i>)	
REPRESENTATIVE	Maharashtra State Pollution Central Board, Mumbai
SHRI S. BALAKRISHNAN	Tamil Nadu Pollution Control Board, Chennai
SHRI A. K. SAXENA	National Productivity Council, New Delhi
SHRI M. A. PATIL (<i>Alternate</i>)	
REPRESENTATIVE	Department of Rural Development, New Delhi
REPRESENTATIVE	Panchayat Raj Department, Hyderabad
DR C. M. AGRAWAL	Directorate General of Health Services, New Delhi
SHRI ASHOK BHATIA	Min of Environment & Forests, New Delhi
DR S. P. PANDE	Water Technology Engineering Div, Nagpur
REPRESENTATIVE	RDSO, Ministry of Railway, Lucknow
SHRI A. K. DEY	Central Fuel Research Institute, Dhanbad
SHRI M. M. MALHOTRA,	Director General, BIS (<i>Ex-officio Member</i>)
Director (Chem)	

Member-Secretary

DR R. K. SINGH

Addl Director (Chem), BIS

